

PERFORMANCE CRITERIA
FOR

SECTION 12 56 70

HEALTHCARE FURNITURE
09/21

TABLE OF CONTENTS

GENERAL

1.1 REFERENCE

2.1 DESCRIPTION & MATERIALS

3.1 SUBMITTALS

3.2 QUALITY ASSURANCE

3.3 STANDARDS DEVIATIONS

3.4 DELIVERY, STORAGE AND PROTECTION

3.5 INSTALLATION, VERIFICATION AND ACCEPTANCE TESTING

3.6 WARRANTY

3.7 OPERATIONS AND MAINTENANCE (O & M)

GENERAL

This Performance Criteria specifies the requirements for healthcare furniture.

1.1 REFERENCE

1.1.1 Unified Facilities Criteria (UFC)

Contractor must comply with the following:

- A. UFC 1-200-01 General Building Requirements
- B. UFC 1-200-02 High Performance and Sustainable Building Requirements
- C. UFC 3-120-10 Interior Design
- D. UFC 4-510-01 Military Medical Facilities

1.1.2 Military Standard

- A. MIL-STD 1691 Construction and Material Schedule for Medical, Dental, Veterinary and Medical Research Laboratories

1.1.3 National Fire Protection Association (NFPA)

- A. NFPA 101 Life Safety Code
- B. NFPA 101 Life Safety Code
- C. NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture
- D. NFPA 701 Standard Methods of Fire Tests for Flame Propagation of Textiles and Films

1.1.4 Military Health System Standards

- A. Reserved for future

1.1.5 American Society for Testing and Materials (ASTM)

- A. ASTM 2503 Standard Practice for Marking Medical Devices and Other Items for Safety in the Magnetic Resonance Environment
- B. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials

1.1.6 American National Standards Institute (ANSI)

- A. ANSI/TIA/EIA-568-C – Commercial Building Telecommunications Cabling Standard
- B. ANSI/TIA-1179 – Healthcare Facility Telecommunications Infrastructure Standard

1.1.7 Underwriters Laboratories (UL)

- A. UL 962A Standard for Furniture Power Distribution Units
- B. UL 1286 Standard for Office Furnishings

1.1.8 International Electrotechnical Commission (IEC)

- A. IEC 60601-2-52 – Medical Electrical Equipment

1.1.8 Business & Institutional Furniture Manufacturers Association (BIFMA)

- A. ANSI/BIFMA x5.5 – Desk Products
- B. ANSI/BIFMA x5.9 - Storage
- C. BIFMA HCF 8.1 – Health Care Furniture Design – Guidelines for Cleanability

1.1.9 Other Standards

- A. APSIC- Guidelines for Environmental Cleaning and Decontamination
- B. CAL-117 (California Technical Bulletin 117-2013)
- C. Reserved for future

2.1 DESCRIPTION & MATERIALS

All requirements within the MIL-STD 1691 JSN descriptions must be met as well as the performance guidelines listed in the following descriptions.

2.1.1 All JSN'S

- A. Fire and flame spread of products must meet class A flame spread with maximum smoke developed of 450 as outlined by testing within the reference standards
- B. All product finishes must be capable of maintaining sheen and color through warranty period when using industry standard cleaning solutions.
- C. Finishes and fabrics will be selected from the manufacturers' standard options for the specified model unless noted otherwise.
- D. Work surface is to be plastic laminate or wood veneer finish. Provide matching vinyl edge for laminate surfaces and veneer edge for the veneer surfaces.
- E. Work surface must be balanced to reduce warping and constructed to accommodate manufacturers' options for keyboard trays, pencil drawers, filing and/or storage. Underside of surface is to be smoothly finished. Products must include a cable management system available.
- F. Storage must be available in a variety of drawer and door configurations. Provide adjustable floor glides or castors.
- G. Wood veneer throughout product must match and hardware must be metal.
- H. Furniture must allow for lockable drawers and/or doors, grommets and integral power/data outlets.
- I. Furniture with electrified equipment must be UL listed and capable of 110/240 volts, 50/60 Hz, Autosensing, unless noted otherwise.
- J. All specified healthcare furniture/casegoods, located within the same department, must be selected so that materials and finishes match, in accordance with manufacturer's selections.

2.1.2 F0354 – Stool, Step, MRI Compatible, w/ Handrail

- A. Step stool, for use in MRI scan room. Constructed of non-ferrous material.
- B. 34 inch minimum height handrail.
- C. Minimum weight capacity is 500 lbs.

2.1.3 F0400 – Cabinet, Bedside, Drawer, Door

- A. Bedside cabinet with one drawer and door for patient storage. Option for three drawers, if desired.
- B. Drawer(s) to be removable to facilitate sanitizing.

2.1.4 F0550 – Armoire, Resuscitation

- A. Infant Resuscitation Armoire used in Labor, Delivery, Recovery/ Labor, Delivery, Recovery, Post-partum (LDR/LDRP).
- B. Armoire must include integrated Infant Warming System, automatic exhaust fan, bassinet or fold-down bed, mounting rails, writing surface, adjustable shelves and drawers for storage.
- C. Options will include integrated flowmeter for suction and oxygen.

- 2.1.5 **F0555 – Wardrobe, Patient Clothing**
 - A. For use in LDR/LDRP or patient rooms
 - B. Furniture for use in storing patient clothing and personal items.
- 2.1.6 **F0560 – Wardrobe, Television**
 - A. For use in LDR/ LDRP or patient rooms.
 - B. Combination wardrobe storage and television cabinet.
- 2.1.7 **F0570 – Dresser, 6 Drawer**
 - A. For storage of patient clothing.
 - B. Provide [metal] [solid wood] drawer glides.
- 2.1.8 **F0799 – Table, Outdoor, Psychiatric**
 - A. For use in Behavioral Health settings
 - B. Provide a minimum 14 gauge steel table top, minimum four integrated backless seats.
 - C. Provide corrosion-resistant with UV stabilized coatings or stainless steel.
- 2.1.9 **F2406 – Bed, Residential, Long Term Care**
 - A. For use in residential Long Term Care setting
 - B. Twin size, Aluminum frame, with head and foot board, finish selected must match other casegoods in the room.
 - C. Provide ergonomic bed sections, hand controls. Interchangeable bed ends, safety rails.
- 2.1.10 **Pediatric Medical Cribs**
 - M3005 – Bassinet, w/Cart**
 - A. Designed for use with infants.
 - B. Cart must be stainless steel construction and mounted on a minimum 3” (8 cm) ball bearing non marking casters.
 - C. Provide basket and mattress/pad.
 - D. Must have a storage drawer.
 - E. Provide design that allows close approach from both sides.
- 2.1.11 **Psychiatric Hospital Beds**
 - M7011 – Bed Platform, Without Visible Legs, Psychiatric**
 - M7012 – Bed, Platform Riser, Psychiatric**
 - A. Durable, one piece, rotationally molded design. Constructed of high impact “no break” material.
 - B. Material must be stain resistant, easy to clean and maintain.
 - C. Must have a means to bolt to the floor.
 - D. Must have the ability to install restraints.
- 2.1.12 **Patient Room Furniture**
 - M7040 – Table, Overbed**
 - A. Adjustable height table constructed of heavy gauge steel designed for use over bed, wheelchair, or large chair.
 - B. Provide adjustable height of 30” – 43”
 - C. Table top constructed of surface material that resists chipping, scratching and staining
 - D. Provide user friendly easy-lift mechanism
- 2.1.13 **Birthing Room Carts**
 - M8960 – Cart, Surgical Case, Birthing Room**
 - A. Customizable surgical case cart for use in birthing rooms. Made to match existing case work in facility.
 - B. Surfaces must be non-porous, impervious to fluids, and allow for thorough cleaning and disinfection.
 - C. Constructed of medical grade material.
 - D. Entire unit mounted on four heavy duty non-marking casters with locking mechanism.
 - M8965 – Cart, Fetal Monitoring, Birthing Room**
 - A. Customizable fetal monitoring cart for use in birthing rooms. Made to match existing case work in facility.
 - B. Surfaces must be non-porous, impervious to fluids, and allow for thorough cleaning and disinfection.
 - C. Constructed of medical grade material.
 - D. Provide ability to mount either single or dual monitor configurations.
 - E. Provide ability to house computer, keyboard, mouse, fetal monitor and bedside supplies.

3.1 SUBMITTALS

3.1.1 Submittals required for government review

- A. Submittal requirements are outlined in [Division 01] [PWS SOW] [___]
- B. [Product Information must include manufacturer's installation instructions, sizing (including required clearance for access and maintenance), utility requirements, isometric drawings, tagged floorplans showing placement for count accountability and accessories/options/consumables lists.]
- C. All submittals require Government approval prior to procurement. Submit all listed items herein, with information sufficient to show full compliance with the criteria. Submit all product selections for review and approval, including but not limited to: materials, finishes, colors, options, accessories, and complimentary products. Provide for review all warranties and service contracts and any available extended warranty or service options.
- D. Samples: Furnish material samples and full range of color selection options for all items that offer material and color selections.
- E. Submit and highlight all applicable options for Government review for all items which optional accessories are provided.
- F. [Joint Interoperability Test Command (JTIC) Approval Documentation.]

3.2 QUALITY ASSURANCE

3.2.1 Materials and Equipment

- A. Materials and equipment must be standard products of a manufacturer regularly engaged in the manufacture of products which are of a similar material, design, and workmanship and are offered for sale on the commercial market through advertisements, manufacturer's catalogs, or sales brochures. The products must have been in commercial or industrial use under similar circumstances and of similar size for 2 years prior to selection for approval/procurement. Products must be supportable for at least three years after government acceptance.

3.2.2 Alternative Service Record

- A. Products having less than a 2-year field service record will be acceptable if a certified record of the manufacturer's factory or laboratory tests demonstrating performance compliance is provided to the Contracting Officer.

3.2.3 Service Support

- A. Equipment items must be supported by service organizations located near the equipment installation, able to service the equipment on a regular basis and respond to emergency calls throughout the warranty period.

3.2.4 Manufacturer's Nameplate

- A. Each item of equipment must have an attached nameplate that is securely affixed in a conspicuous space. A nameplate listing only the name of the distributing agent is not acceptable. The nameplate must contain the following fields in English:

1. Manufacturer's name and address
2. Model and Serial Number
3. Item's utility ranges and/or capacities
4. Voltage, amperage, and applicable Underwriters Laboratory (UL) or Conformité Européenne (CE) rating if electrically powered
5. Date of manufacture

3.2.5 Factory Inspection

- A. Arrange and perform all quality control and quality assurance inspections required by the technical sections of the criteria, unless otherwise specified. Report these inspections in the daily report to the Government inspector.

3.2.6 Product Qualifications

- A. The products specified in the technical sections of this criteria establish standards for each item.

3.2.7 Design Parameters

- A. It is not the intention of this Criteria to limit consideration to products of specific manufacturers. The product standards establish the characteristics for which submitted items of equipment will be reviewed and approved by the Government. Equipment furnished must meet each of the following parameters specified in the technical sections:

1. Size of equipment

2. Function of equipment
3. Standard and listed accessories and options
4. Equipment controls and performance of equipment
5. Construction of equipment
6. Finish

3.3 STANDARDS DEVIATIONS

3.3.1 Reporting and Submission for Approval

- A. Submit for approval a record of deviations from the standards listed in section (3.2.7.A.) established for each specified product, before ordering equipment.

3.4 DELIVERY, STORAGE AND PROTECTION

3.4.1 Packaging and Transporting

- A. Each unit of equipment must be placed in a substantial shipping container or crate for safe transportation to final destination. The shipping container or crate for heavy equipment must be on skid construction to facilitate handling by lift equipment.

3.4.2 Packing List

- A. Clearly and legibly indicate on exterior of each container or crate the shipping address and a brief description of contents. Fasten to outside of container a packing list and complete instructions for uncrating equipment and setting it in place. Protect such information in a weatherproof envelope.

3.4.3 Protection

- A. Properly protect all materials and equipment from injury and damage during storage, installation, and acceptance.

3.5 INSTALLATION, VERIFICATION AND ACCEPTANCE TESTING

3.5.1 Qualifications of Installers and Inspectors

- A. If required by product warranty, use installers that are approved and licensed by the manufacturer. When required to complete installation, all electricians and plumbers used must be bonded and licensed in the project's jurisdiction.
- B. [Company specializing in installing the products specified in this section must have a minimum 5 years of documented experience.]
- C. [Company specializing in installing the products specified in this section must be within 200 miles or 4 hours travel time.]

3.5.2 Installation, Operation, Testing and Certification

- A. Products must be delivered in manufacturer's original packaging with manufacturer's installation instructions. Include clearly marked project reference.
- B. Prior to installation, thoroughly examine the equipment, materials, and components for both visual defects and conformance with criteria.
- C. Install all equipment in compliance with manufacturer's written instructions and installation procedures.
- D. After installation, the equipment must be inspected and tested under operating conditions. If the equipment fails an inspection or test, such defects/failures must be corrected. Upon correction of defects/failures, inspect and retest all affected functions related directly and indirectly to the defect or failure. Corrections, replacement, and retesting must be made at no additional expense to the Government.
- E. Provide all items necessary to make equipment fully functional.
- F. Provide appropriately trained personnel to energize, commission, inspect, electrical safety check, calibrate, certify, and provide all required technical testing for equipment and systems. Contractor must provide documentation, test reports and certification documentation attesting that the equipment is properly installed, functional, safe, calibrated, and ready for its intended use.
- G. An equipment item will be considered defective if it cannot be made to meet all established criteria consistent with the activities listed in section (F).
- H. Provide two sets of special tools, software, and any other item/s for each equipment [item] [item type] if required for maintenance and/or future reconfiguration of the item.
- I. Contractor to supply all start-up supplies for medical equipment for a fully operational installation. Contractor must supply to the Government a listing of all needed supplies for ongoing equipment operation for each item of equipment requiring additional supplies for operation.

- J. Engage a factory-authorized service representative to train Government's staff and maintenance personnel to adjust, operate, and maintain medical equipment.
- K. [Confirm functionality of required interfaces to other systems and networks.]

3.6 WARRANTY

3.6.1 Minimum Requirements

- A. Warranty requirements are outlined in [Division 01] [PWS SOW] [____].
- B. [Provide manufacturer's written warranty for all items listed. Provide warranty for a minimum of (1) year against defects in materials and workmanship. Warranty must provide for material, labor and all associated replacement and/or repair costs required to provide for a fully operational equipment replacement or repair. Submit manufacturers and installers standard service contract beyond the warranty period for Government review. Warranty must be transferrable to the final owner without risk of being voided. All warranty certification and documentation must be provided to the final owner after date of acceptance.]
- C. Provide routine warranty service in accordance with manufacturer's warranty requirements, for a period of [12 months (minimum)] [____] after the open for business date. Perform work during regular working hours. Perform service only by factory trained personnel. Maintain a maintenance log of all service orders performed during the warranty period.

3.7 OPERATIONS AND MAINTENANCE (O & M)

3.7.1 Provide the following to the final owner

- A. Provide O & M data for all FFE-LVS as outlined in [Division 01] [PWS SOW] [____].
- B. Upon completion of equipment installation, furnish [two (2)] copies of operators/service/maintenance manuals for each type of equipment which will require service or maintenance
- C. Each manual must contain operating instructions and information required for performing periodic maintenance on the equipment. Each service manual must include an illustrated parts breakdown which identifies each part of the unit with manufacturer's part number, wiring diagrams, and a list of necessary service parts, tools, and equipment needed to support maintenance requirements.
- D. Accessory Catalogs: Upon completion of the Project, furnish two copies of the manufacturer's catalogs containing optional accessory items available for all equipment relative to the procured equipment/system delivered herein.
- E. Provide instruction video for cleaning and maintenance, when available.
- F. Provide cleaning requirements for all items to prevent void of warranty.
- G. [Provide contact information for Repair Technician or Emergency Repair Company]
- H. Provide contact information to [Logistics, Pharmacy, Laboratory, and Biomedical Equipment Services.]
- I. Train designated staff in the operation and maintenance of the provided equipment/system. Provide two training sessions for equipment/system users and two training sessions for maintenance personnel scheduled to accommodate shift work. [Provide training certificates that can be executed up to eleven months after the system is installed, in order to provide a refresher course for each group of trainees.] Provide DVD copy of the training with the O & M data.

--End of Section--