

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-26 28 01.00 10 (August 2021)

Preparing Activity: USACE

-----  
Superseding  
UFGS-26 28 01.00 10 (October 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2021

\*\*\*\*\*

SECTION TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

SECTION 26 28 01.00 10

COORDINATED POWER SYSTEM PROTECTION

08/21

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SYSTEM DESCRIPTION
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
  - 1.4.1 System Coordinator

PART 2 PRODUCTS

- 2.1 COORDINATED POWER SYSTEM PROTECTION
  - 2.1.1 Scope of Analyses
  - 2.1.2 Determination of Facts
  - 2.1.3 Single Line Diagram
  - 2.1.4 Fault Current Analysis
    - 2.1.4.1 Method
    - 2.1.4.2 Data
    - 2.1.4.3 Fault Current Availability
  - 2.1.5 Coordination Study
  - 2.1.6 Study report

PART 3 EXECUTION

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-26 28 01.00 10 (August 2021)

Preparing Activity: USACE

-----  
Superseding  
UFGS-26 28 01.00 10 (October 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2021

\*\*\*\*\*

SECTION 26 28 01.00 10

COORDINATED POWER SYSTEM PROTECTION  
08/21

\*\*\*\*\*

NOTE: This guide specification covers the requirements for the coordinated protection of power systems.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

PART 1 GENERAL

1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also

use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE 242 (2001; Errata 2003) Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems - Buff Book

IEEE 399 (1997) Brown Book IEEE Recommended Practice for Power Systems Analysis

## 1.2 SYSTEM DESCRIPTION

\*\*\*\*\*

NOTE: Provide brief, general description of the electrical power system project.

Coordinate with Section 26 11 14.00 10 MAIN ELECTRIC SUPPLY STATION AND SUBSTATION; Section 33 71 01 OVERHEAD TRANSMISSION AND DISTRIBUTION; Section 33 71 02 UNDERGROUND ELECTRICAL DISTRIBUTION; Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM; Section 26 08 00 APPARATUS INSPECTION AND TESTING.

\*\*\*\*\*

The power system covered by this specification consists of: [\_\_\_\_\_].

## 1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the

Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are [for Contractor Quality Control approval.][for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-03 Product Data

Fault Current Analysis

Protective Device Coordination Study

System Coordinator

1.4 QUALITY ASSURANCE

1.4.1 System Coordinator

System coordination, recommended ratings and settings of protective devices, and design analysis must be accomplished by a registered professional electrical power engineer with a minimum of [3] [\_\_\_\_\_] years of current experience in the coordination of electrical power systems. Submit verification of experience and license number, of a registered Professional Engineer as specified above. Provide experience data consisting of at least five references for work of a magnitude comparable to this contract, including points of contact, addresses and telephone numbers.

PART 2 PRODUCTS

2.1 COORDINATED POWER SYSTEM PROTECTION

\*\*\*\*\*

**NOTE:** The requirements for the studies in these paragraphs depend on the complexity and extent of the power system. Delete these requirements for: projects of limited scope; projects having protective devices which are not adjustable or for which coordination is not possible (standard molded case circuit breakers); projects involving simple

extension of 600 volt level service to a building or facility from an existing transformer (750 kVA or less); or projects involving simple extension of 600 volt level service to a building or facility from a new transformer (750 kVA or less).

The designer will be responsible for showing and specifying the requirements for fuses, circuit breakers, protective relays, or other protective devices associated with the project. The protective devices should be selected and specified to protect electrical power system conductors or equipment against sustained overloads, in-rush conditions, electrical faults, or other abnormal power system or equipment operating conditions, in accordance with UFC 3-520-01, IEEE 242, and IEEE Std 141.

The complexity and extent of coordinated power system protection depends on the type of buildings or facilities required, on the load demand of facilities, and on the quantity and types of facilities to be constructed. Facilities having a relatively-low power demand (e.g., 2500 kVA or less) generally require protection of: an incoming aerial distribution line or underground, medium-voltage feeder; low-voltage feeders to individual items of equipment, or to power distribution equipment, and branch circuits. More complex projects such as facilities with generating capacity, large motors, or larger load demands, will require more detailed and extensive coordinated power system protection.

Independent of the type or types of facilities or load demands, the coordinated power system protection will be based on: economics, simplicity, and the electrical power availability dictated by the Using Agency or Service, or by the functional use of the facilities or utilities; requirement to provide maximum power service with a minimum of power interruptions; and the operating speed of protective devices required to minimize damage to electrical components or items of equipment and to prevent injury to personnel and nuisance tripping.

Unless otherwise approved, a dc power source will be shown and specified to ensure proper closing and tripping of protective devices which require a reliable power source during outage of the normal alternating-current power source.

\*\*\*\*\*

Prepare analyses to demonstrate that the equipment selected and system constructed meet the contract requirements for ratings, coordination, and protection. Include a load flow analysis, a [fault current analysis](#), and a [protective device coordination study](#). Submit the study along with protective device equipment submittals. No time extensions or similar contact modifications will be granted for work arising out of the requirements for this study. Approval of protective devices proposed will be based on recommendations of this study. The Government is not

responsible for any changes to equipment, device ratings, settings, or additional labor for installation of equipment or devices ordered and/or procured prior to approval of the study. The studies must be performed by a registered professional engineer with demonstrated experience in power system coordination in the last [3] [\_\_\_\_\_] years. Provide a list of references complete with points of contact, addresses and telephone numbers. The selection of the engineer is subject to the approval of the Contracting Officer.

#### 2.1.1 Scope of Analyses

The fault current analysis and protective device coordination study must begin at: [the source bus and extend down to system buses where fault availability is 10,000 amperes (symmetrical) for building/facility 600 volt level distribution buses.] [the source bus and extended through the secondary side of transformers for medium voltage distribution feeders.] [the source bus and extend through [outgoing breakers] [outgoing medium voltage feeders, down to the individual protective devices for medium voltage radial taps] [outgoing medium voltage feeders, through the secondary side of transformers] [as indicated] for main electric supply substations.] [the nearest upstream device in the existing source system and extend through the downstream devices at the load end.]

#### 2.1.2 Determination of Facts

\*\*\*\*\*  
**NOTE: Require the Contractor to obtain an available fault capacity at the power source or provide a fault capacity on which to base the analysis. Delete the unused option.**  
\*\*\*\*\*

Determine and document the time-current characteristics, features, and nameplate data for each existing protective device. [Coordinate with the [commercial power company] [\_\_\_\_\_] for fault current availability at the site.] [Utilize the fault current availability indicated as a basis for fault current studies.]

#### 2.1.3 Single Line Diagram

Prepare a single line diagram to show the electrical system buses, devices, transformation points, and all sources of fault current (including generator and motor contributions). A fault-impedance diagram or a computer analysis diagram may be provided. Each bus, device or transformation point must have a unique identifier. If a fault-impedance diagram is provided, show impedance data. Show location of switches, breakers, and circuit interrupting devices on the diagram together with available fault data, and the device interrupting rating.

#### 2.1.4 Fault Current Analysis

##### 2.1.4.1 Method

Perform the fault current analysis in accordance with methods described in [IEEE 242](#), and [IEEE 399](#).

##### 2.1.4.2 Data

Utilize actual data in fault calculations. Bus characteristics and

transformer impedance must be those proposed. Document data in the report.

#### 2.1.4.3 Fault Current Availability

Provide balanced three-phase fault, bolted line-to-line fault, and line-to-ground fault current values at each voltage transformation point and at each power distribution bus. Show the maximum and minimum values of fault available at each location in tabular form on the diagram or in the report.

#### 2.1.5 Coordination Study

Demonstrate that the maximum possible degree of selectivity has been obtained between devices specified, consistent with protection of equipment and conductors from damage from overloads and fault conditions. Include a description of the coordination of the protective devices in this project. Provide a written narrative describing: which devices may operate in the event of a fault at each bus; the logic used to arrive at device ratings and settings; situations where system coordination is not achievable due to device limitations (an analysis of any device curves which overlap); coordination between upstream and downstream devices; and relay settings. Provide recommendations to improve or enhance system reliability, and detail where such changes would involve additions or modifications to the contract and cost damages (addition or reduction). Provide composite coordination plots on log-log graph paper.

#### 2.1.6 Study report

- a. Include a narrative describing: the analyses performed; the bases and methods used; and the desired method of coordinated protection of the power system.
- b. Include descriptive and technical data for existing devices and new protective devices proposed. Include manufacturers published data, nameplate data, and definition of the fixed or adjustable features of the existing or new protective devices.
- c. Document [utility company data including system voltages, fault MVA, system X/R ratio, time-current characteristic curves, current transformer ratios, and relay device numbers and settings;] [and] [existing power system data including time-current characteristic curves and protective device ratings and settings].
- d. The report must contain fully coordinated composite time-current characteristics curves for each bus in the system, as required to ensure coordinated power system protection between protective devices or equipment. Include recommended ratings and settings of all protective devices in tabulated form.
- e. Provide the calculation performed for the analyses, including computer analysis programs utilized. Provide the name of the software package, developer, and version number.

### PART 3 EXECUTION

Not Used

-- End of Section --