



NATIONAL GUARD BUREAU
3501 FETCHET AVENUE
JOINT BASE ANDREWS MD 20762-5157

31 Mar 2024

MEMORANDUM FOR DISTRIBUTION

FROM: NGB/A4

SUBJECT: Air National Guard Engineering Technical Letter (ANGETL) 24-01-03: Fire Protection Design Guidance

1. PURPOSE: This ANGETL provides guidance in implementing the Air National Guard (ANG) fire protection design policy.

2. APPLICABILITY

2.1. **Effective date:** Immediately

2.2. Intended Users: Base Civil Engineers (BCE) and Architect-Engineering contractors (A-E).

2.3. This ETL shall be applicable for all new designs, designs for which NGB/A4I formal approval of the Type A-2 Concept Development Submittal has not yet been issued and for all code and criteria review. Application of this ANGETL for projects that have obtained formal approval of the Type A-2 Submittal shall be on a case-by-case basis and as directed by the NGB/A4I Project Manager.

2.4. Hierarchy

2.4.1. Air National Guard (ANG) fire protection policy is based on codes and standards as outlined in UFC 1-200-01 DoD Building Code (General Building Requirements) in addition to this and other ANGETLs. Other fire codes are applicable only where required, such as per a lease agreement. When conflict occurs between applicable codes the most stringent applies.

2.4.2. The hierarchy of applicable codes and standards is in accordance with UFC 1-200-01 DoD Building Code (General Building Requirements). This ANGETL provides additional design requirements or alternative design methods but does not supersede UFC requirements.

2.5. Authority Having Jurisdiction

- 2.5.1. The terms “Building Official”, “Code Official”, and “*Authority Having Jurisdiction*” (AHJ) as used in the codes and standards, and referenced in this ANGETL, means the component office of responsibility NGB/A4. The DOD Unified Facilities Criteria (UFC) 1-200-01 has further defined it to the chief engineer office.
- 2.5.2. NGB/A4IC Civil Engineer Technical Branch (CETB) serves as the Fire Protection Subject Matter Expert for NGB/A4.
- 2.5.3. The enforcement of the codes and standards as they pertain to facility projects may be delegated to the local Components Office’s Chief Engineer’s Technical Representative at the discretion of the NGB/A4.
- 2.5.3.1. When delegated it confers the authority to interpret the codes and standards and not the authority to waive and/or exempt requirements specifically provided in the documented codes and standards.

2.6. Designated (or Service) Fire Protection Engineer

- 2.6.1. The term *Designated Fire Protection Engineer* (DFPE) as used in this ANGETL and other UFCs, means the fire protection engineer of the component office of responsibility such as the Air National Guard, NGB/A4IC Civil Engineer Technical Branch (CETB).
- 2.6.2. The DFPE responsibilities may be delegated to the local Components Office’s Chief Engineer’s Technical Representative at the discretion of the component’s office. The Technical Representative is preferred to be a registered professional engineer (P.E) who has passed the fire protection engineering written examination administered by the National Council of Examiners for Engineering and Surveying (NCEES) and has relevant fire protection engineering experience or at a minimum who meets the requirements of the Civilian Job Series 0804.

3. QUALIFIED FIRE PROTECTION ENGINEER (QFPE)

- 3.1. Qualified Fire Protection Engineer (QFPE). An individual who is a registered professional engineer (P.E.) who has passed the fire protection engineering examination administered by the National Council of Examiners for Engineering and Surveying (NCEES) and has relevant fire protection engineering experience.
- 3.1.1. The QFPE can act as the designer of record and/or quality control representative for fire protection matters.
- 3.1.2. ANG projects require a QFPE for the design, review and oversight services as outlined in the UFC 3-600-01 Fire Protection Engineering for Facilities.

- 3.1.3. For design-bid-build projects, provide a QFPE for the design development including design drawings, specifications, and preliminary calculations. The construction contractor shall provide an independent QFPE during construction for shop drawings, final calculations, inspections and testing.
- 3.1.4. The QFPE is responsible for all life safety system components and occupant loads to include oversight and approval of recommended deviation to NGB
- 3.1.5. For design-build projects, provide a single QFPE throughout the project.
- 3.1.6. ANG construction (shop) drawings and calculations must be prepared by NICET III or IV, SET, CET must be prepared under the immediate supervision of, the QFPE. The QFPE must affix their professional engineering stamp with signature to the shop drawings, calculations and material data sheets, indicating approval prior to submitting the fire suppression, fire alarm, Emergency Services systems, fire stopping with penetrations of 5 or more through fire rated walls and systems being shown on a floor plan with wall type and penetration material and third-party fire stopping design with material shown, system shop drawings to the DFPE. The QFPE must monitor the installation of all of the above and witness all testing including fire rated dampers and certify in writing that the fire above system has been constructed and operates as intended in the design plans and specifications.

3.2. Exemptions and Equivalencies

- 3.2.1. When requesting an *Exemption* or *Equivalency*, include written justification in accordance with UFC 1-200-01 DOD Building Code.
- 3.2.2. Exemptions or equivalencies for operational fire protection must be coordinated through NGB/A4XF must be coordinated IAW ANGI 32-2001 & DODI 6055.8

4. REFERENCE PUBLICATIONS: Refer to Attachment 1 for a list of referenced publications

5. GENERAL

- 5.1. Air National Guard (ANG) fire protection policy is based on current Federal and Department of Defense criteria. Items noted in this document include guidance, clarifications and preferences for issues specific to ANG facilities. All fire protection designs shall follow current Unified Facilities Criteria (UFC) requirements.
- 5.2. Qualified Fire Protection engineer shall be required for all projects contained in the UFC 3-600-01, Change 6 or later, and AFI 32-10141. See AFI 32-10141, PLANNING AND PROGRAMMING FIRE SAFETY DEFICIENCY CORRECTION PROJECT, AFI 32-10141 matrix when to use a QFPE shall be responsible for fire and life safety analysis including infrastructure for each project.

5.3. Delegated Design

- 5.3.1. At minimum, include the following for delegated fire suppression design.
- 5.3.1.1. A legend defining the symbols and abbreviations used. Fire suppression notation as required for specific design and installation requirements of the system.
 - 5.3.1.2. Provide the available fire water supply and other related requirements such as fire pumps and fire water storage.
 - 5.3.1.3. Plans/layouts indicating sprinkler zones, hazard classifications for each area, design densities and design areas, hose demand, and additional information required to define the performance limitations of the fire suppression systems.
 - 5.3.1.3.1. All working (shop) drawings, regardless of the type of fire suppression system, must meet the drawing requirements in NFPA 13 for Working Drawings, unless the system specific standard has requirements for working drawings.
 - 5.3.1.4. Where fire pumps are used, provide an enlarged plan locating major equipment such as fire pumps, risers, and major piping runs within the fire protection room.
 - 5.3.1.5. Where a fire pump or more than one riser is used in a building, provide a one-line diagram indicating the intended infrastructure of the system including items such as valves, flow/pressure switches, tamper switches, pumps, riser assemblies, bypasses, backflow prevention, fire department connection, test header, and surge suppression.
 - 5.3.1.6. Fire suppression specifications.
 - 5.3.1.7. Preliminary hydraulic calculations demonstrating an adequate fire water supply is provided. Additional calculations may be required by other UFCs.
- 5.3.2. At minimum, include the following for delegated Fire Alarm and Mass Notification design.
- 5.3.2.1. A legend defining the symbols and abbreviations used. Fire alarm notation as required for specific design and installation requirements of the system.
 - 5.3.2.2. Plans/layouts shall be provided to define the performance limitations of the fire alarm system.
 - 5.3.2.2.1. Indicate the location of items such as fire alarm control units, releasing system fire alarm control units, notification appliance booster panels, amplifiers, pull stations, aspirating smoke detection panels, and spot smoke detection.

- 5.3.2.2.2. Provide the location of coordinated fire safety devices such as door hold opens, fire/smoke dampers, and spot smoke detection for elevator recall.
- 5.3.2.2.3. The specific location of notification appliances is not required, however indicate what areas require audible and/or visible notification.
- 5.3.2.2.4. Coordinate with the fire suppression plans/layouts for connections such as tamper switches, flow switches, and pressure switches.
- 5.3.2.3. Provide details/elevations as required to relay specific design and installation requirements, such as a start station layout.
- 5.3.2.4. Provide a one-line diagram showing the intended infrastructure of the fire alarm system. At a minimum, show how panels are connected to each other and associated subpanels. Indicating how each type of device or appliance is connected to its associated panel or subpanel. Showing multiple connections of the same type of device or appliance on a panel is not required.
- 5.3.2.5. Provide a fire alarm matrix for each fire alarm control unit or releasing system fire alarm control unit demonstrating the functionality of connected devices.
- 5.3.2.6. When applicable, provide the language for voice evacuation and mass notification messages.
- 5.3.2.7. Fire alarm specification

6. DESIGN CRITERIA

- 6.1. All design, and construction projects which involve or impact fire detection and suppression systems for ANG facilities, especially those involving the design of aircraft hangar fire suppression systems, require the designer (A-E or in-house), and contractor to have on staff, or under contract, a qualified and experienced Fire Protection Engineer (FPE). For the purpose of meeting qualification requirements, a qualified FPE is defined as an individual meeting the requirements of UFC 3-600-01, Fire Protection Engineering for Facilities.
- 6.2. UFC 3-600-01, Fire Protection Engineering for Facilities requirements regarding renovations, alterations, rehabilitations and modernizations shall be followed, in addition to more specific guidance provided in this document. Changes in occupancy are required to comply with requirements for new construction.
- 6.3. Use components that are Underwriter's Laboratory (UL) Listed or Factory Mutual (FM) approved for fire protection service in the design and construction of fire suppression and fire alarm systems.

6.3.1. Exception: UL Listed or FM Approved components are not required where specifically approved by this ANGETL, other UFCs, or tested by a Nationally Recognized Testing laboratory (NRTL) to the satisfaction of the AHJ.

6.3.2. Exception: UL Listed or FM Approved components are not required where specifically exempted in NFPA standards.

7. FIRE ALARM AND MASS NOTIFICATION SYSTEMS

- 7.1. Automatic detection systems shall be kept to the minimum required by the referenced standards from this document.
- 7.2. The fire alarm system shall provide radio based, fiber optic or landline based, remote system reporting to the base central system, and a secondary central receiver. Provide radio based transmission systems for all new base-wide systems. Retrofit installations shall use system equipment that is listed by a nationally recognized testing laboratory, and is compatible with the existing equipment to include the central base transmitting and receiving system. All facility fire alarm systems must also transmit appropriate signals to the responding (host or other) fire department, which in most cases is the ANG fire station.
- 7.3. All fire detection and alarm system conductors shall be run in minimum 3/4 in. electrical metallic tubing (EMT) conduit. Exception would be those locations deemed unsuitable for EMT conduit. In such cases, use rigid or PVC type conduit. Use of flexible metal conduit (FMC) or liquid-tite conduit is not permitted except in areas subject to extreme vibration, and where used, shall be limited to 6 ft. Lengths.
- 7.4. For ICD/ICS design utilize CPVC Pipe and 10 thin wall steel with dielectric break for piping sizes greater than 2 inches in diameter. For pipes below 2 inches in diameter utilize a schedule 40 with dielectric break.
- 7.5. Systems shall utilize supervised non-proprietary generic type detection devices and notification appliances and shall be interchangeable with other brands that are readily available to the extent practical.
- 7.6. Notification circuits in sleeping areas, and indicating device circuits for sleeping quarters, shall be on Class A or X circuits as defined in National Fire Protection Association (NFPA) 72. Positive alarm sequence shall be used following parameters established in NFPA 72
- 7.7. All detection and terminal devices shall have engraved plastic or metallic alphanumeric identification, which shall be keyed to the posted operations and maintenance instructions.
- 7.8. Manual pull stations shall be provided, at a minimum, at each exit as defined in NFPA

- 7.8.1. 72. Do not provide pull stations on the hinged side of doors except in the case of double doors.
- 7.9. At all locations that a duct detector is installed, provide remote test switch (install at a maximum of 7 feet above finish floor (AFF) elevation) and LED indicator for maintenance and alarm identification.
- 7.10. The fire alarm control panel for each facility's detection system shall be located in a room with outside access, either the fire protection, mechanical, or electrical rooms. Coordinate the locations of the fire panel and annunciator panel (if required) with the BCE and Fire Chief.
- 7.11. Fire Alarm panels shall be field expandable. Panels may be field programmable provided that this can be accomplished at the unit (panel) level, without the use of proprietary software, keys, the changing of electronic hardware, or use of any proprietary device. Any software, device, password or other element used to program any component of the fire alarm system shall be specified to become property of the government, along with the installed program.
- 7.12. Emergency eyewash and shower station connection to the fire alarm system will be determined by the Base Fire Chief. If provided with connections to the fire alarm system, these stations shall report as a supervisory alarm and not as a trouble alarm.

8. FIRE SUPPRESSION SYSTEMS

- 8.1. Fire suppression systems shall be wet pipe or dry pipe, and the design shall be based on the hazard involved. Pre-action systems are strongly discouraged, and wet pipe systems are recommended in lieu of pre-action systems.
- 8.2. In no case shall the A-E use any source data (fire department, water purveyor, or BCE) for water supply information other than an actual test witnessed and accepted by the A-E representative.
- 8.3. The following component details shall be designed into all suppression systems
- 8.3.1. All steel piping for the fire suppression system shall be minimum schedule 40 thickness.
- 8.3.2. Provide dedicated fire service entrance with back-flow prevention device and indicating shut off valve. All fire service utility entrance shall be separate from facility domestic water supply utility entrance. This separation does not need to be split exterior to the building. If spacing permits do not put exterior to the building for maintenance purposes. ANG preference for incoming service is a single stainless-steel service.
- 8.3.3. Fire suppression system auxiliary drain valves shall be fully accessible and located no higher than 7'-0" AFF.

- 8.3.4. For all projects, design of supports for fire protection systems shall comply, as a minimum, with seismic criteria as outlined in the UFC requirements.
- 8.3.5. All wall and floor penetrations for fire protection piping shall be fully sleeved and sealed.
- 8.3.6. Sprinklers shall be located symmetrically within ceiling tiles. Provide architecturally coordinated, single piece sprinkler trim rings in occupied spaces.
- 8.3.7. For fire hydrants, on Air Force and Reserve bases where the ANG is a tenant, follow host base style and color policy.
- 8.3.8. Sprinklers for server rooms shall be standard response intermediate temperature classification.
- 8.3.9. All fire sprinkler risers shall be located in rooms with direct access to the exterior of the building, such as mechanical rooms.

9. PASSIVE FIRE PROTECTION SYSTEMS (LIFE SAFETY SYSTEMS) - SCIF

- 9.1. Secure Compartmented Information Facilities (SCIF) and similar spaces shall comply with NFPA Standard 101 requirements for life safety.
- 9.2. Hardware shall be from approved lists by USACE Huntsville SCIF unless otherwise authorized by AO. The listing of approved hardware can be found within Federal Specification FF-L 2890.
- 9.3. ICD/ICS 705 perimeter doors & hardware shall be purchased as a complete rated assembly to preserve reserve STC unless otherwise authorized by AO.

10. HANGAR FIRE PROTECTION

- 10.1. Piping design shall show consideration (unions or flanged connections) for the removal of pumps, valves and other items for maintenance.

11. FIRE SYSTEM APPURTENANCES

- 11.1. Fire protection design for all facilities shall include the following listed features and items.
 - 11.1.1. Provide Knox (or equivalent type) boxes, located on the exterior of the building at a location to be determined by the BCE and the Base Fire Chief. The box shall be cast brass, recessed style and suitable for housing appropriate keys.
 - 11.1.2. Provide fire extinguisher cabinets in accordance with UFC 3-600-01, Fire Protection Engineering for Facilities. All extinguisher cabinets shall be recessed or

semi-recessed style with eased corner and glass face. Cabinets shall be specified to be of heavy duty brushed stainless steel construction. Cabinets shall be specified to accommodate the size extinguishers that will be provided by the base fire department. Extinguishers are government furnished (GF) items.

11.1.3. IAW AFMAN 91-203 Fire Extinguisher Purchase and Maintenance. Facility managers and using organizations shall budget for purchase and maintenance of fire extinguishers.

11.1.4. Fire Prevention Inspectors review facility plans to ensure required fire protection features are present, response vehicles have appropriate access, and local emergency response elements are incorporated in design. IAW UFC 3-600-01, they shall not conduct the required Fire Protection Engineer reviews of technical designs.

12. SPECIFICATIONS

12.1. Specifications shall require the contractor(s) to provide the following:

12.1.1. The contractor shall provide their own confirming water flow testing where an existing water system is being used in the design.

12.1.2. Identification and operations identifications that are coordinated with and keyed to the posted operations instructions and the operation & maintenance (O&M) manuals.

12.1.3. O&M manuals shall be completed, submitted and approved by no later than 30 days prior to beneficial occupancy.

12.1.4. Posted instructions shall comply with any UFC/NFPA requirements but also include the following for Air National Guard installations at a minimum:

12.1.4.1. Comprehensive schematics for sprinkler distribution systems.

12.1.4.2. Facility floor plans showing location of all fire equipment and devices with coordinated identification. Show items such as fire walls, fire dampers etc.

31 Mar 24

- 12.1.4.3. System diagrams, including isometrics of special equipment and systems.
 - 12.1.4.4. Valve charts.
 - 12.1.4.5. Equipment schedule.
 - 12.1.4.6. Wiring diagrams and schematics.
 - 12.1.4.7. Fire/smoke dampers.
 - 12.1.5. Posted Operations Instructions, framed in heavy gauge extruded metal frames, mounted under glass. These posted instructions shall be water/weatherproof Instructions shall be permanently mounted in the reserved clear wall area (show reserved area in the design drawing details) in each fire protection room or mechanical room.
 - 12.1.6. Posted instructions completed with professionally prepared graphics, printed on full size sheets and shall be in color. Instructions shall be prepared for all fire protection systems and shall include all components.
 - 12.1.7. Training for Base personnel on all fire detection and suppression systems. Training shall be specified to be complete with all materials, fees and tuition paid for by the contractor. Employee travel costs shall be paid for by the government.
 - 12.1.8. A professionally edited DVD for training on all "special" systems. Editing shall include voice-over editing describing features and action of the depicted system.
13. **POINT OF CONTACT:** The point of contact for this ANGETL is CETB Fire Protection NGB/A4IC at (701) 857-4398, DSN 344-4398, or email NGB CETB Workflow

X 

Signed by: USAF

CHAD R. CALLAN, GS-15, DAF, P.E.
Associate Director, Engineering
National Guard Bureau

Attachment:
References

Distribution: Each USPFO Each BCE